



The top slab borders will be protected in the unloading areas on all floors. The protection will only be taken away for loading and unloading the material and will be replaced before any movement of the platform.



## IDENTIFICATION OF RISKS

- Collapse of the platform.
- Falling into open space.
- Getting trapped.
- Fall of the load.
- Getting trapped by mobile parts.
- Electrocution by contact with electrical energy.

## RISKS AND PREVENTION INFORMATION

### LIFT



 Instituto Regional de Seguridad y Salud en el Trabajo  
CONSEJERÍA DE EMPLEO Y MUJER  
**Comunidad de Madrid**

Instituto Regional de Seguridad y Salud en el Trabajo  
C/ Ventura Rodríguez, nº 7. 28008 Madrid  
Teléfono: 900 713 123 Fax: 914 205 808  
www.madrid.org



 **Comunidad de Madrid**



This will not be used for the transport of people, only for lifting or lowering materials.



The inferior area of the lift will be closed off to prevent the passage of people during upwards or downwards movement of the platform.



The lift cable winding drum and any other area with mobile parts will be protected to avoid risk getting trapped.

